

Printed on: 17 Jan 2013

Registration No.	1944
Title	Beamfast FD60
Status	Authorised For Use
Supersedes ProductID	N/A
Superseded By ProductID	N/A
Date Authorised for Use	12 Dec 2012
Primary Use	Manufacturer of timber fire doors, fire-rated (30 and 60 minute) doorsets, accepted for installation in LU Premises (stations and depots)
Additional Info/KeyWords	Beamfast Limited, Unit F, Forest Industrial Park, Forest Road, Hainault, Essex, IG6 3HL. Tel: 020 8502 7700. www.beamfast.co.uk. Beamfast is a BM Trada approved manufacturer and installer of timber fire-rated doorsets with or without glazing systems. Doorsets provide fire integrity as defined in BS 476: Part 22: 1987. Beamfast also has ISO 9001 certification and complies with the Forestry Stewardship Council Chain of Custody System and the Programme for the Endorsement of Forest Control. This fire door has been accepted for use in sub-surface locations under concession by LUL.
Classification Hierarchy	Premises Buildings Buildings
Manufactured By	Beamfast Limited

Requirements

ReqID	Requirement	Status	Trial
No records to display.			

Conditions

Description	Linked To ReqID
For fire protection, the installation of the doorset shall be carried out by an installer, recognised under a suitable third party certification scheme, in accordance with the manufacturers' instructions. These instructions should enable the installer to fit the product correctly and allow checks to be undertaken by the LU fire engineer.	
The ironmongery for the doorset should be in accordance with LU Guidance Document G0134B and accepted by the manufacturer as achieving the required fire resistance as a system.	

Evidence

EvidenceText	EvidenceType	FileName	Linked To ReqID
BM Trada Certification for the manufacture of timber fire rated door sets that comply with BS 476: Part 22.	Consultation	Timber Fire Door Manufacturer Certificate (April 2014).pdf	
ISO 9001 Certificate for the Design and Supply of Timber Door Sets	Consultation	ISO 9001 - Quality Management Certificate (11th Jan 2011 - 10 Jan 2014).pdf	
Fire Resistance Data for Beamfast Flamebreak 60 Door Sets	Test report	Chiltern Fire Test Report.pdf	
BM Trada Certificate for FSC Chain of Custody System	Consultation	FSC Certificate (Aug 2007 - Aug 2017, Issue No.4).pdf	
BM Trada Certificate for the PEFC Chain of Custody System	Consultation	PEFC Certificate (Aug 2007 - Aug 2017, Issue No.4).pdf	

Refer to Web site www.lu-apr.co.uk to check current status, download attachments and for details of other products.

MAYOR OF LONDON